



# **Johnson Controls**

### **Expanded range**

The State guidelines set the normal range at five degrees (69°F to 74°F) with a max offset of one degree. You are allowed to heat less or cool less than the normal band because it saves energy.







## **Johnson Controls**

#### Dial

#### Dial Centered (5°F neutral band)

- the system will heat up to 69°F
- the system will cool down to 74°F
- the system will not heat or cool between
  69°F and 74°F with airflow at minimum

#### Rotating all the way to the left

- the heating set point will drop to 55°F (linear scale between 55°F and 69°F)
- the cooling set point will drop to 73°F

### Rotating all the way to the right

- the heating set point will rise to 70°F
- the cooling set point will rise to 85°F
  (linear scale between 73°F and 85°F

